

**INTERGOVERNMENTAL WASTEWATER
TECHNICAL REVIEW COMMITTEE
THURSDAY FEBRUARY 11TH, 2025 10:00AM *TEAMS*
CONFERENCE ROOM 214**

Attendees: Perry Hart, Tracy Myers, Rodney Clifton, Steve Skalski, Laveta Hardish, Chaz Wilkey, Ben Kladder (Fleis & Vanderbrink)

Other attendees: Sarah McGinnis

Call to order: Chairperson Tracy Myers (Emmett) called the meeting to order at 10:03am

Approval of agenda: Do not have quorum

Approval of minutes: Do not have quorum – approve minutes from 11/12/24 and 2/11/25 at next meeting on May 13, 2025

Pump Station Update:

O-2 Edgebrook Capital Improvement: Perry Hart stated the Edgebrook PS is operating parallel with the old system for two weeks. With no issues, the old system will go offline and the new system will be fully operational with generator installed.

Pump Station O-15 Minges Creek: Perry Hart stated the Minges PS is fully operational. The completion will allow evaluations and repairs on the 18" force main.

Contributing Jurisdiction Update: Rodney Clifton reviewed the current spreadsheet of sanitary work orders.

Member Updates: Email any member contact updates to Sarah McGinnis

Adjourned: 10:15am